

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8715

1. OWNER Steve Rabbeck ADDRESS AT WELL LOCATION 1110 Angel Chambers Field  
 MAILING ADDRESS 1110 Angel Chambers Field  
 2. LOCATION NW 1/4 S1E 1/4 Sec. 17 T. 12 N. 30 Douglas County  
 PERMIT NO. 2766414 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil & overburden		0	9	9
Gravel w/ boulders	✓	9	93	84
brown clay		93	97	4
Gravel w/ boulders	✓	97	110	13
brown to tan clay		110	117	7
Gravel w/ sand	✓	117	142	25

8. WELL CONSTRUCTION  
 Diameter hole 10 3/8 inches Total depth 142 feet  
 Casing record 6 5/8" P.D.  
 Weight per foot 11.6 lb/ft Thickness 1 1/2  
 Diameter From To  
6 5/8 inches ±2 feet 142 feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 52 feet  
 Gravel packed: Yes  No   
 Gravel packed from 52 feet to 142 feet  
 Perforations:  
 Type perforation Mill Slot  
 Size perforation 3/32 x 3 1/2"  
 From 116 feet to 136 feet

Date started 4-30 1986  
 Date completed 5-1 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Removed drill mud and developed well with air</u>			

9. WATER LEVEL  
 Static water level 17 feet below land surface  
 Flow 30 G.P.M. P.S.I.  
 Water temperature 62.1 °F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name P.D. Pump Co. Contractor  
 Address P.O. box 3432 Contractor  
 Nevada contractor's license number 23295  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 1472 Actual Driller

BAILER TEST

G.P.M.	Draw down	feet	hours

Signed Quinton R. Butts Contractor  
 Date 5/5/86