

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8465

1. OWNER JACK NORMAN ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3691 PEACOCK COURT #1  
SANTA CLARA, CALIF. 95051  
 2. LOCATION SW 1/4 NE 1/4 Sec 13 T 19 N/S R. 27 E Churchill County \_\_\_\_\_  
 PERMIT NO. NCWE Parcel No. 710113 Subdivision Name NCWE  
Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVERBURDEN</u>	<u>0</u>	<u>0</u>	<u>12</u>	<u>12</u>
<u>CLAY, BROWN</u>	<u>0</u>	<u>12</u>	<u>34</u>	<u>22</u>
<u>BROWN, SAND, FINE</u>	<u>34</u>	<u>34</u>	<u>45</u>	<u>11</u>
<u>GRAY, BROWN SAND, FINE</u>	<u>0</u>	<u>45</u>	<u>49 1/2</u>	<u>4 1/2</u>
<u>CLAY, BROWN</u>	<u>0</u>	<u>49 1/2</u>	<u>54 1/2</u>	<u>5</u>
<u>GRAVEL, GRAY</u>	<u>9</u>	<u>54 1/2</u>	<u>56 1/2</u>	<u>2</u>

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 56'-8" feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 58'-4"  
 Weight per foot \_\_\_\_\_ Thickness .188  

Diameter	From	To
<u>6</u> inches	<u>18"</u>	<u>56'-8"</u>
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type NEAT  
 Depth of seal 25 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Jerch.  
 Size perforation 5/32 x 3"  
 From 53'-4" feet to 58'-4" feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 9-1 1986  
 Date completed 9-3 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3450</u>	<u>23</u>	<u>15</u>	<u>5 hrs</u>

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 9'-6" feet below land surface  
 Flow none G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature 50 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WATER-RITE WELL DRILLING  
 Address P.O. Box 883 Fallon, NV. 89406  
 Nevada contractor's license number issued by the State Contractor's Board 0023978  
 Nevada contractor's driller's number issued by the Division of Water Resources 1473  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473  
 Signed Gerald H. Olson  
 By driller performing actual drilling on site or contractor  
 Date 9-3-86