

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **7398**

PRINT OR TYPE ONLY

1. OWNER Bill Clennell ADDRESS AT WELL LOCATION 15 Rayo De Sol Court
 MAILING ADDRESS 2001 Glendale Ave.
Sparks, Nv 89431

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T 21 N/S R 20 E Washoe County Spanish Springs
 PERMIT NO. 76-390-50 Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic rock and clays		0	11	11
mostly clay with some sand slight green tint		11	156	145
clay with sand brownish tan color		156	172	16
brown clay and sand		172	248	76
green jumbo clay		248	258	10
T.D. 258'				

8. 10" - 50' WELL CONSTRUCTION

Diameter hole 8 inches Total depth 258 feet
 Casing record 6 5/8"
 Weight per foot 10.98 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>2 +</u> feet	<u>258</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 258 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 218 feet to 238 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 160 feet below land surface
 Flow 24 G.P.M. P.S.I. _____
 Water temperature cool °F. Quality clear

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller

Date started 9/3/86, 19_____
 Date completed 9/3/86, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop.			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Roger M. Thrall
 Roger M. Thrall Contractor
 Date 9-4-86