

OFFICE USE ONLY
 Log No. 27745
 Permit No. _____
 Basin 6-BB

CCDS

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7402

PRINT OR TYPE ONLY

1. OWNER Bill Krone ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4500 Mira Loma #271 15856 Fawn Lane
Reno, Nv 89502

2. LOCATION 1/4 NE 1/4 Sec 136 T18 N/S R. 19 E Washoe County
 PERMIT NO. 150-242-03 45-070-68
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. sands fine		0	80	80
D.G. fine sands mixed with volcanic gravel		80	157	77
T.D. 157				
There is a 20' blank at the bottom of the perforated pipe				
<i>see deepening log # 111375</i>				
<i>39.376, 390°N MAG 27 D.O.</i>				
<i>119.804, 413°W</i>				

8. 10" - 55' WELL CONSTRUCTION
 Diameter hole 8 1/2 inches Total depth 156 feet
 Casing record 6 5/8
 Weight per foot 10.78 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>156</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 156 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 116 feet to 136 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9/16/86, 19____
 Date completed 9/16/86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

9. WATER LEVEL
 Static water level 80 feet below land surface
 Flow 30+ G.P.M. P.S.I. _____
 Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc. Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132 Actual Driller
 Signed Roger M. Thrall Contractor
 Date 9/17/86

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours