

OFFICE USE ONLY
 Log No. 27661
 Permit No. _____
 Basin Coal Truckee Canyon

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7690

1. OWNER PAT McLAUGHLIN/K&K BUILDERS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1080 Linda Way Hunkin Cir
Sparks, NV 89431 Verdi, NV
 2. LOCATION SW 1/4 NW 1/4 Sec. 18 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. 38-082-09
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay with boulders		0	9	9
Brown clay		9	16	7
Soft sandy granite sands		16	23	7
Boulder, gravels with brown clay		23	40	17
Dark brown clay		40	96	56
Gray clay		96	112	16
Soft zone	X	112	114	2
Gray clay		114	120	6
Soft zone	X	120	122	2
Gray clay		122	123	1
Dark brown clay		123	143	20
Soft zone (NO WATER)		143	145	2
Dark brown clay		145	165	20
Soft zone	X	165	167	2
Dark brown clay		167	180	13
Gray clay		180	185	5
Soft zone	X	185	188	3
Gray clay		188	203	5

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 203 feet
6 inches
5 inches
 Casing record 203
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>150</u> feet
<u>5 9/16</u> inches	<u>143</u> feet	<u>203</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type ceement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 203 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 105 feet to 145 feet
163 feet to 203 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9-22-86, 19____
 Date completed 9-23-86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL
 Static water level 47 feet below land surface
 Flow 40 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date September 29, 1986