

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7114

1. OWNER Darrel Grause ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS Box 1251 \_\_\_\_\_  
Minchen Nu 89423 \_\_\_\_\_  
2. LOCATION 1/4 1/4 Sec. 33 T. 13 N/S R. 21 E. Douglas County  
PERMIT NO. 35-341-02 Parcel No. \_\_\_\_\_ Subdivision Name Fish Springs

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation   
Municipal  Industrial

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Cobbles &amp; Clay</u>		<u>0</u>	<u>30</u>	
<u>Sand &amp; Clay</u>		<u>30</u>	<u>35</u>	
<u>Cobbles &amp; Clay</u>		<u>35</u>	<u>65</u>	
<u>Clay Sand &amp; Cobbles</u>		<u>65</u>	<u>115</u>	
<u>Cobbles, Sand &amp; Clay</u>		<u>115</u>	<u>140</u>	

8. WELL CONSTRUCTION  
Diameter hole 8 inches Total depth 140 feet  
Casing record \_\_\_\_\_  
Weight per foot \_\_\_\_\_ Thickness .187  
Diameter From To  
8 inches 0 feet 140 feet  
\_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
Surface seal: Yes  No  Type Cement  
Depth of seal 50 feet  
Gravel packed: Yes  No   
Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Perforations:  
Type perforation Artery feet  
Size perforation 3 x 5/32  
From 117 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 30 25' feet below land surface  
Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold ° F. Quality Good

Date started 9/1 1986  
Date completed 9/11 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Kauchack Drilling Inc Contractor  
Address 1578 Chiquita de Minchen Nu 89423 Contractor  
Nevada contractor's license number 021268  
Nevada contractor's drillers number 1380  
Nevada driller's license number 1380 Actual Driller  
Signed Eddy & Kauchack Contractor  
Date 9/13/86

BAILER TEST  
G.P.M. 20+ Draw down 4 feet 1 hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours