CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 27784
Permit No.
Basin 49

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 34 N/S R. 55 E County
PERMIT NO. 27-007-90022
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELS & CLAYS,		0	45'	45'
SOME MINOR AMOUNTS				
OF MUDSTONE				
CLAYS, GRAVELS, ANGULAR		45	60	20'
CHIPS UP TO .5cm, MUDSTONE				
CLAYS, MUDSTONE		60	62	2'
GRAVELS, ≤ 1/8", qtz,		62	80	18'
SHALE & FELDSPARS				
GRAVELS ≤ 1/4", CLAYS	83'9"	80	120	40'
INCREASING to 40%				
CLAYS, 40% GRAVELS, ≤ 1/8"		120	125	5'
GRAVELS, ANGULAR to SUB		125	185	60'
ROUNDED CHIPS, REDDISH				
BRN. SILTY CLAYS 20-50%				
GRAVELS, 60-90%, REDDISH		185	240	55'
BROWN SILTY CLAYS VARYING				
FROM 10-30%.				5
GRAVELS, ¾ to SUBROUNDED		240	290	50'
≤ 1/8", 20% CLAYS				
GRAVELS, ¾ to SUBROUNDED		290	350	60'
≤ 1/4", 20% REDDISH				
BROWN SILTY CLAYS				

Date started ....., 19....
Date completed ....., 19....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450 (ST. DD)	60	27.52	12
(ST. DD)	30	11.34	8
(ST DD)	15	6.42	4
(CONST)	50	14.93	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ..... inches Total depth 240 feet
Casing record
Weight per foot ..... Thickness 250

Diameter	From	To
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☑ No ☐ Type grout
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ..... Contractor
Address ..... Contractor
Nevada contractor's license number C14410
Nevada contractor's drillers number
Nevada driller's license number ..... Actual Driller
Signed ..... Contractor
Date

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O 627 CR434