

OFFICE USE ONLY  
 Log No. 277861  
 Permit No.  
 Basin Gal Truckee Canyon sed.

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO.

1. OWNER KORVISH TRUST ADDRESS AT WELL LOCATION 400 Bridge St  
 MAILING ADDRESS HOO BRIDGE ST Verdi, Nev  
 2. LOCATION 1/4 Sec. 8 T. 19 N/S R. 18 E Washoe County  
 PERMIT NO. 37-550-22 Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material                  | Water Strata | From | To  | Thick-ness |
|---------------------------|--------------|------|-----|------------|
| sand, gravel              |              | 0    | 29  | 29         |
| sandy, clay. Br.          |              | 29   | 74  | 45         |
| grey clay                 |              | 74   | 164 | 90         |
| grey shale                |              | 164  | 172 | 8          |
| fractured shale           | x            | 172  | 175 | 3          |
| soft shale w/ clay layers | x            | 175  | 236 | 61         |
| fractured shale           | x            | 236  | 251 | 15         |
| shale & clay              |              | 251  | 281 | 30         |
| fractured shale           | x            | 281  | 305 | 24         |

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 305 feet  
 Casing record  
 Weight per foot 9 Thickness 1156  
 Diameter From To  
6 7/8 inches 0 feet 305 feet

Surface seal: Yes  No  Type sand & cement grout  
 Depth of seal 64 feet  
 Gravel packed: Yes  No   
 Gravel packed from 64 feet to 305 feet

Perforations:  
 Type perforation factory sawed  
 Size perforation 3 3/8 x 2 1/2  
 From 205 feet to 245 feet  
 From 285 feet to 305 feet

9. WATER LEVEL

Static water level approx. 50 feet below land surface  
 G.P.M. approx. 12  
 Water temperature unknown ° F. Quality unknown

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Paul E. Williams & Sons Contractor  
 Address 22 So. Patterson Sparks Nev Contractor 89431  
 Nevada contractor's license number 14483  
 Nevada contractor's drillers number 957  
 Nevada driller's license number 957 Actual Driller  
 Signed Paul E. Williams Sr. Contractor  
 Date 10-7-86

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

BAILER TEST

G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours  
 G.P.M. Draw down feet hours