

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7709

1. OWNER STEVE GATES ADDRESS AT WELL LOCATION 3381 BOYER ROAD FALLON NEVADA
 MAILING ADDRESS 3381 BOYER ROAD FALLON NEVADA
 2. LOCATION SW 1/4 NW 1/4 Sec 4 T. 19 N. R. 28 E Churchill County
 PERMIT NO. 006-291-90 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0'	10'	10'
CLAY		10'	14'	4'
SAND		14'	17'	3'
CLAY		17'	20'	3'
SAND		20'	39'	19'
CLAY		39'	40'	1'
• TULE SAND		40'	50'	10'
BROWN CLAY		50'	51'	1'
SAND & GRAVEL	WATER	51'	74'	23'
BROWN CLAY		74'		

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 74 feet
 Casing record _____
 Weight per foot _____ Thickness 15.6

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>5.0</u> feet
<u>8</u> inches	<u>0</u> feet	<u>74</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type CEMENT
 Depth of seal 5.0 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation MACHINE D
 Size perforation 1/2 x 3
 From 6.2 feet to 74 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F. Quality Good

Date started Oct 9, 1986
 Date completed Oct 11, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name VERNON CANNON JR Contractor
 Address 1870 ROBERSON, LN FALLON Contractor
 Nevada contractor's license number 23317
 Nevada contractor's drillers number 1455
 Nevada driller's license number 1455 Actual Driller
 Signed Vernon Cannon Jr Contractor
 Date Oct 11, 1986

BAILER TEST
 G.P.M. 32 Draw down 6 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours