

OFFICE USE ONLY
 Log No. 27801
 Permit No. _____
 Basin B-103

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER Paul W. Howard ADDRESS AT WELL LOCATION 260 Imperial Rd
 MAILING ADDRESS SHARON Bx 1233 Dayton NV 89403

2. LOCATION NE NE 1/4 Sec 9 T. 16N R. 22E County Dayton

PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	
D/G		3	28	
BROWN CLAY		28	65	
SAND + GRAVEL	X	65	72	
BROWN CLAY		72	93	
SAND + GRAVEL	X	93	107	
CLAY		107	125	

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 125 feet
 Casing record 8 3/8
 Weight per foot _____ Thickness 156
 Diameter _____ From _____ To _____
12 inches 0 feet 53 feet
8 inches 53 feet 125 feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type CEMENT
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32
 From 95 feet to 115 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 60 feet below land surface
 Flow No G.P.M. _____ P.S.I. _____
 Water temperature COLD F. Quality UNKNOWN

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W.M. Blain Well Drilling Contractor
 Address Bx 353, Dayton NV 89403 Contractor
 Nevada contractor's license number 10950
 Nevada contractor's drillers number 1118
 Nevada driller's license number 1436 Actual Driller
 Signed W.M. Blain Contractor
 Date 21 August 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 20 Draw down 0 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours