

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 8209

PRINT OR TYPE ONLY

1. OWNER Frank Roberts ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 350 S. Center St. Suite 450 7895 Kevin Lane  
Reno, Nv 89501  
 2. LOCATION NE 1/4 SE 1/4 Sec 2 T 17 N/S R. 19 E Washoe County  
 PERMIT NO. 41-251-06 - Cottonwood Estates  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Clay-hard-brown		3	91	88
Clay[brown] & volcanic sands		91	121	30
Volcanic rock hard		121	128	7
Volcanic sands mixed with layers of brown clay and frequent rock fragments		128	151	23
Sticky brown clay		151	156	5
There is a 12' blank at the bottom of the casing string				
T.D. 156				

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 156 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 5/8"  
 Weight per foot 10.78 & 12.92 Thickness .156 & .188  

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>156</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type slurry  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to 156 feet  
 Perforations:  
 Type perforation screen  
 Size perforation .030  
 From 134 feet to 144 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 12/2/86, 19\_\_\_\_\_  
 Date completed 12/3/86, 19\_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL  
 Static water level flowing feet below land surface  
 Flow 70+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
Contractor  
 Address 2255 Glendale Ave. Sparks, NV 89431  
Contractor  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board.  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources.  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1132  
 Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 12/4/86