WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27844
Permit No.
Basin WASHOE V. - 89 -

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1372

1. OWNER DERALD PARKS
MAILING ADDRESS 215 PINTAIL WAY CARSON CITY, NV 89701
ADDRESS AT WELL LOCATION 215 PINTAIL WAY CARSON CITY, NV 89701

2. LOCATION NE ¼ SE ¼ Sec. 32 T. 17 N/S R. 20 E. WASHOE County
~~PERMIT NO.~~ WASHOE Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Cemented gravel | | 16 | 172 | 12 |
| Cemented gravel Small amount of water | ✓ | 172 | | |
| Brown clay | | 172 | 177 | 5 |
| Cemented gravel with [illegible] | ✓ | 177 | 190 | 13 |
| Granite | | 190 | | |
| T.D. 190 | | | | |

Date started SEPT 18, 1986
Date completed SEPT 18, 1986

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| BLEW WELL TO DEVELOP & CLEAN FOR 2 HRS | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth ..... feet
Casing record 4½"
Weight per foot ..... Thickness .134

| Diameter | From | To |
|---|---|---|
| 4½ inches | 160 feet | 190 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal Unknown feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation FACTORY
Size perforation 3/32 X 3
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 82 feet below land surface
Flow 21 G.P.M. ..... P.S.I.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H PUMP Co
Contractor
Address 5551 Hwy 52 E C. City Unit 5
Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number .....
Nevada driller's license number 1472
Actual Driller
Signed [signature]
Contractor
Date SEPT 23, 1986

(Rev. 6-81)

USE ADDITIONAL SHEETS IF NECESSARY

O-627 CR434