WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27845
Permit No.
Basin 89 - WASHOE V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1311

1. OWNER David (Hunt) Goodin
MAILING ADDRESS 429 Annette St
Sacramento, Calif 95841

ADDRESS AT WELL LOCATION 4115 Woodcreek
Carson City, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 31 T. 17 N/S R. 20 E Washoe County

PERMIT NO. Washoe | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Consolidated gravel picked up somewhat granular in places	Y	214	260	46
Water seams from 230 to 260				

Note: Existing well was 3' below ground level. Extended casing to 15" above existing ground level to meet code.

Date started Sept 17, 1986
Date completed Sept 17, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew dirt for 2 hrs with 125 psi air to clean well clean			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 260 feet
Casing record 4½"
Weight per foot ..... Thickness .134

Diameter	From	To
6 inches	214 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal Unknown feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Louvre
Size perforation 3/32" x 5"
From 214 feet to 260 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... feet below land surface
Flow 25 G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co (Contractor)
Address 3351 Highway 52 Unit 3 Carson City, Nevada (Contractor)
Nevada contractor's license number 23095
Nevada contractor's drillers number
Nevada driller's license number 1477
Signed Vernon X. Beck (Actual Driller) (Contractor)
Date Sept 23, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434