WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27872
Permit No.
Basin 8-105 Carson V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7414

1. OWNER Charles Jones
MAILING ADDRESS 2030 Fish Spring Rd
Gardnerville, NV

ADDRESS AT WELL LOCATION
MARTY WAY
Gardnerville, NV

2. LOCATION NW ¼ NW ¼ Sec. 35 T. 13 N/S R. 20 E. Douglas County

PERMIT NO. _____ Issued by Water Resources | 23-290-22 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden | | 0 | 2 | 2 |
| | | 2 | 62 | 60 |
| Clay, very tight | | | | |
| tight Sand | | 62 | 80 | 18 |
| Sand and pea gravels | ✓ | 80 | 120 | 40 |
| Totald depth | | | | 120 |

Date started Oct 29, 1986
Date completed Oct 30, 1986

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| developed with air for 1½ | | | |
| or to clean well | | 30+ GPM | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 to 50 inches Total depth 120 feet
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 42 feet | 120 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Factory Cut
Size perforation 3/32 x 3½
From 100 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 25 feet below land surface
Flow 30+ G.P.M. ..... P.S.I.
Water temperature Cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co.
Contractor
Address 5551 Hwy 50 E #3 C. City
Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Actual Driller
Signed Quinton R Butts
Contractor
Date 11/3/86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434