

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8027

PRINT OR TYPE ONLY

1. OWNER DENNIS BALAAM ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2745 West View Same
Sparks, NV 89431

2. LOCATION NE 1/4 NE 1/4 Sec 2 T 19N N/S R. 20 E Sparks Washoe County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand, gravel & boulders		0	7	7
Brown clay with smaller gravels		7	10	3
Light brown clay		10	31	21
Brown clay		31	80	49
Reddish brown volcanic rock		80	105	25
Brown volcanic rock		105	130	25
Black hard volcanic rock		130	144	14
Brown clay		144	163	19
Brown volcanic rock		163	178	15
Brown clay		178	260	82
Soft zone	X	260	265	5
Brown weathered volcanic rock		265	323	58
Soft zone		323	328	5
Brown weathered volcanic rock		328	345	17
Black volcanic rock		345	438	93
Black blue-gray rock with clay streaks		438	446	8
Black volcanic rock		446	460	14
Soft blue-gray clay		460	469	9
Black volcanic rock		469	473	4
Soft blue-gray clay		473	475	2

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 475 feet
6 inches
6 inches

Casing record 475 ft. installed
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>475</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 475 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around

From	feet to	feet
<u>240</u>	<u>260</u>	<u>feet</u>
<u>340</u>	<u>350</u>	<u>feet</u>
<u>450</u>	<u>470</u>	<u>feet</u>
_____	_____	_____
_____	_____	_____

Date started 10-22-86, 19____
 Date completed 10-27-86, 19____

9. WATER LEVEL

Static water level 130 feet below land surface
 Flow 9 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549 issued by the State Contractor's Board.
 Nevada contractor's driller's number 908 issued by the Division of Water Resources.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date October 31, 1986

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours