

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 8201

PRINT OR TYPE ONLY

1. OWNER Walton Bernhardt ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3705 B Lisa 230 Dortort Rd  
Reno, Nv 89503 Virginia City Highlands

2. LOCATION NE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 32 T. 18 N/S R 21 E Storey County  
 PERMIT NO. 003-051-05 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown		0	2	2
Purple and white decomposed rock		2	15	13
Blue, gray and white decomposed rock		15	30	15
Purple and white rock with little clay		30	95	65
Green, purple and brown rock		95	125	30
Purple and white rock with traces of green		125	165	40
Green and brown decomposed water bearing rock		165	180	15
T.D. 180				

8. 10" - 50' WELL CONSTRUCTION  
 Diameter hole 8  $\frac{1}{4}$  inches Total depth 180 feet  
 Casing record 6 5/8"  
 Weight per foot 10.70 & 12.72 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>180</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 180 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started October 28, 1986, 19\_\_\_\_  
 Date completed October 29, 1986, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop			

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Flow 30+ G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc. Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller  
 Signed Roger M Thrall Contractor  
 Date 11/3/86

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours