



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO.

PRINT OR TYPE ONLY

1. OWNER Ron Correll ADDRESS AT WELL LOCATION 68 S RAINBOW  
 MAILING ADDRESS Bx 1024, Dayton NV 89403

2. LOCATION N 1/4 S 1/4 Sec 27 T 17 N/S R. 22 E LYON County  
 PERMIT NO. lot 2 PINEHART VIEW Estates Subdivision Name  
 Issued by Water Resources Parcel No.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	
SAND		3	8	
BROWN CLAY		8	22	
Clay & SAND mixture		22	67	
GRAVEL & SAND	X	67	118	
BROWN CLAY		118	123	

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 123 feet  
 Casing record 8 5/8  
 Weight per foot 14.11 Thickness .156

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>56</u> feet
<u>8</u> inches	<u>0</u> feet	<u>123</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Reed. Mix  
 Depth of seal \_\_\_\_\_ feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation Factory Slot  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 53 feet below land surface  
 Flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Cold ° F. Quality unknown

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name W. M. Blain Well Drilling Contractor  
 Address Bx 353, Dayton NV 89403 Contractor  
 Nevada contractor's license number 10950  
 Nevada contractor's drillers number 1118  
 Nevada driller's license number 1436 Actual Driller  
 Signed W. M. Blain  
 Date November 1986

Date started October 19 86  
 Date completed November 19 86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 Draw down 4 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours