WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 279/07
Permit No.
Basin 8-105 Carson V.

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7319

1. OWNER R. Bakman
MAILING ADDRESS 213 Annapolis Carson City, NV

ADDRESS AT WELL LOCATION 7207 S. Center Lane Carson City, NEVADA

2. LOCATION NW ¼ SE ¼ Sec. 5 T. 14 N/S R. 20 E Carson City County
PERMIT NO. (Issued by Water Resources) 9311-29 (Parcel No.) NONE (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blue clay		0	3	3
Sand with thin clay seams		3	63	60
Sand, clay gravels w/ small amount of water	✓	63	67	4
Clay interspersed with sand, brown in color		67	85	18
Clay, sand (gray), gravels to 3/8" carrying water	✓	85	138	53
Hard tan to brown cemented gravel no water		138	140	2
T.D. = 140'				

Date started Nov 18, 1986
Date completed Nov 21, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well to clean and develop well for 3 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 3/4 inches Total depth 140 feet
Casing record 6 5/8 O.D.
Weight per foot 11.7/FT Thickness .156

Diameter	From	To
6 5/8 inches	+2- feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 140 feet

Perforations:
Type perforation Mill Slot Factory
Size perforation 3/32 x 3 1/2"
From 85 feet to 133 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 23 feet below land surface
Flow 10 G.P.M. ..... P.S.I.
Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. Contractor #3
Address 5551 Hwy 50 Carson City, NV 89701 Contractor
Nevada contractor's license number 13225
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Clinton R. Brett Actual Driller / Contractor
Date Nov 21, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434