WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27931
Permit No.
Basin 6-88 Pleasant V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 220

1. OWNER WAYNE JANNKE
MAILING ADDRESS RENO, NEVADA
ADDRESS AT WELL LOCATION 5420 GOLDEN ROD RENO, NEVADA

2. LOCATION SW ¼ NW ¼ Sec. 5 T 17 N/S R 19 E WASHOE County
PERMIT NO. ~~[illegible]~~ Issued by Water Resources | Parcel No. | CALLAHAN RANCH Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN WITH LARGE BOULDERS		0	5	5
BOULDERS WITH SMALLER STONES TO 6" AND SAND		5	80	75
LOOSE PEA GRAVEL & SAND & GRAVELS WITH SMALL ROCKS TO 3" DIAMETER	✓	80	120	40
TOTAL DEPTH 120'				
MAIN WATER FROM 90' TO BOTTOM OF WELL	✓			

Date started Dec 1, 1986
Date completed Dec 4, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well to clean, develop and gravel pack for 4 hours with 450 CFM 250 PSI			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4" to 80 inches Total depth 120 feet
Casing record 6 5/8"
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 56 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 56 feet to 120 feet

Perforations:
Type perforation MILL SLOT, FACTORY
Size perforation 3/32" X 3 1/2"
From 94 feet to 114 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 49 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. Contractor
5551 Hiway Sec #3
Address Carson City, NV 89701 Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472 Actual Driller
Signed Quinton R. Batts Contractor
Date Dec 4, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434