WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27933
Permit No.
Basin 89-WASHOE V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7385

1. OWNER LEHMAN L. BOOHER
MAILING ADDRESS 305 SPARROW WAY
CARSON CITY, NV

ADDRESS AT WELL LOCATION SPARROW WAY
CARSON CITY, NV

2. LOCATION NE ¼ SE ¼ Sec. 32 T. 17 N/S R. 26 E. WASHOE County
PERMIT NO. (Issued by Water Resources) 50-392-05 (Parcel No.) NEW WASHOE CITY UNIT 5 LOT 14 BLK 5 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY TOP SOIL W/SMALL ROCK		0	8	8
SANDY D.G. COMPACTED TO VERY FIRM		8	187	179
GRANITE, WEATHED W/SMALL AMOUNT OF WATER	—	189	191	2
GRANODIORITE, HARD,		191	230	39
FRACTURED GRANODIORITE WITH WATER	—	230	243	13

Date started DEC 8, 1986
Date completed DEC 10, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
BLEW WELL WITH AIR TO DEVELOP & GRAVEL PACK 23 GPM FROM 18' PUMPED WELL - DRAWDOWN 9' TO 155' @ 15 GPM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4" inches Total depth 243 feet
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	243 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 52 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 52 feet to 243 feet

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3/32 x 3 1/2
From 218 feet to 238 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 146 feet below land surface
Flow 23 G.P.M. ..... P.S.I.
Water temperature COLD °F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
5551 Hillary St. #3
Address CARSON CITY, NV 89701 (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472 (Actual Driller)
Signed Quinton R Butts (Contractor)
Date Dec. 11, 1986

(Rev. 6-81)
USE ADDITIONAL SHEETS IF NECESSARY
O-627 CR434