


OFFICE USE ONLY
 Log No. 27941
 Permit No. _____
 Basin 163



WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1206

1. OWNER WARREN KNIGHT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 640 HCR 70 JEAN NV 89019

2. LOCATION SE 1/4 SE 1/4 Sec 16 T. 25 N/S R. 57 E CLARK County _____
 PERMIT NO. _____
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------|--------------|------|----|------------|
| SANDY LOAM | | 0 | 13 | 13 |
| SAND | | 13 | 23 | 10 |
| CLAY | | 23 | 31 | 8 |
| CALICHE | | 31 | 34 | 3 |
| CLAY | | 34 | 40 | 6 |
| CALICHE | WTR | 40 | 42 | 2 |
| CLAY | | 42 | 46 | 4 |
| SAND | WTR | 46 | 52 | 6 |
| LOOSE ROCK SAND | WTR | 52 | 60 | 8 |

8. WELL CONSTRUCTION
 Diameter hole 14 inches Total depth 60 feet
 Casing record _____
 Weight per foot 12.5 Thickness 1.56

| Diameter | From | To |
|--------------------|---------------|----------------|
| <u>8.75</u> inches | <u>0</u> feet | <u>60</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 60 feet
 Perforations:
 Type perforation FLAME CUT
 Size perforation 1/8 X 1/4" 6 ROWS
 From 50 feet to 60 feet
 From _____ feet to _____ feet

RECEIVED
 NOV 14 1986
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started OCT 30, 1986
 Date completed NOV 10, 1986

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST
 G.P.M. 32 Draw down 11 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 31 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 68 ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name RCBB INC. Contractor
 Address 1701 W. CHARLSTON LAS VEGAS NV 89102 Contractor
 Nevada contractor's license number 020301
 Nevada contractor's drillers number 1352
 Nevada driller's license number 1352 Actual Driller
 Signed Robert Spurbek Contractor
 Date NOV 13 - 86