WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27961
Permit No.
Basin 212

PRINT OR TYPE ONLY

In Roof

NOTICE OF INTENT NO. 24

1. OWNER Ruth Specht
MAILING ADDRESS 4310 Blue Diamond Rd
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 20 T. 22 S N/S R. 61 E. CLARK County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders + Brn Clay		0	25	25
Part Cemented gravel		25	60	35
Brn Clay Boulders + gravel		60	145	85
Light Tan Clay & gravel w/ Boulders		145	213	68
Boulders + Brn Clay		213	217	4
Brn Clay + gravel		217	248	31
Partially cemented gravel	X	248	253	5
Red Clay + gravel		253	263	10
Partial Cemented gravel	X	263	300	27
Primary Water	X	276	—	

RECEIVED
JUL 24 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started MAY 17, 1986
Date completed MAY 20, 1986

7. WELL TEST DATA

~~Pump RPM~~	G.P.M.	Draw Down	After Hours Pump
Air	50	—	3 hrs.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 5/8 inches Total depth 308 feet
Casing record
Weight per foot ..... Thickness 156

Diameter	From	To
8" inches	+1.5 feet	302 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 55 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation ¼ x 7
From 239 feet to 302 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 185 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 58 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name J & M Well Service (Contractor) — Murrell Redding
Address 236 Mesa Verde Ln. (Contractor)
Nevada contractor's license number 020295
Nevada contractor's drillers number
Nevada driller's license number 1478
Signed Murrell Redding (Actual Driller / Contractor)
Date 5-21-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434