WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

In Book

OFFICE USE ONLY
Log No. 27975
Permit No. 50316
Basin 216

NOTICE OF INTENT NO. 2470

1. OWNER Georgia Pacific Corp.
MAILING ADDRESS 133 Peachtree St. N.E.
Atlanta, Georgia,

ADDRESS AT WELL LOCATION Appex

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 18S N/S R. 63 E Clark County
PERMIT NO. 50316 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cemented conglomerate		0	91	91
gravel		91	98	7
grey clay		98	160	62
cemented conglomerate		160	218	58
grey clay & gravel		218	258	40
grey clay		258	270	12
cemented conglomerate		270	279	9
black rock		279	301	22
grey lime		301	395	94
white clay		395	416	21
grey lime & quartz		416	620	204
grey lime & streaks clay		620	801	181
grey lime	X	801	1035	234
white & grey clay		1035	1040	5
2" caving gravel	XX	1040	1045	5
black rock		1045	1050	5
grey lime	XX	1050	1160	10
red rock & clay		1160	1168	8
grey lime		1168	1205	37

RECEIVED
OCT 1 2 1986
Div. of Water Resources
Search Office - Las Vegas, NV

Date started Sept. 8, 1986
Date completed Sept 30, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	72	?	24

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 10" inches Total depth 1205' feet
Casing record 6 5/8"
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8" inches	+18" feet	1205 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 55 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation Torch
Size perforation 3/16 x 6"x3 arount
From ____ feet to ____ feet
From 754 feet to 1205 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 660' feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ ° F. Quality ____

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling Inc. (Contractor)
Address 4847 So. VAlley View Blvd. (Contractor)
Nevada contractor's license number 018917
Nevada contractor's drillers number 1301
Nevada driller's license number 1376 (Actual Driller)
Signed [signature] (Contractor)
Date October 13, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434