


27994

WELL DRILLERS REPORT

Please complete this form in its entirety



PRINT OR TYPE ONLY

1. OWNER Frank & Sharon Dennison ADDRESS AT WELL LOCATION
 MAILING ADDRESS Pahrump, Nevada 89041

2. LOCATION SE 1/4 SE 1/4 Sec 18 T 21-S N/S R 54 E Nye County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
White Clay		4	24	20
Light Brown Clay		24	52	28
White Clay	x	52	68	16
Hard Lime		68	74	6
Light Brown Clay	x	74	96	22
Grey Clay	x	96	132	36
Brown Clay		132	140	8

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 140 feet
 Casing record 140 ft. of 8 in. casing
 Weight per foot 18 lbs. Thickness .188

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 140 feet
 Perforations:
 Type perforation Torch Cut
 Size perforation 1/2 in width 8 in long
 From 80 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED
 NOV 3 1986
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started October 12, 1986
 Date completed October 12, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 48 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address St. Rt. Box 36525 Contractor
 Nevada contractor's license number 7484
 Nevada contractor's drillers number _____
 Nevada driller's license number 725 Actual Driller
 Signed Charles Nyberg Contractor
 Date October 25, 1986

BAILER TEST
 G.P.M. 20 gals. Draw down 4 feet 1/2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours