WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Replacement in Bo

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28001
Permit No. 48614
Basin 212

1. OWNER Chris W Jones (DALE + DOROTHY)
MAILING ADDRESS

NOTICE OF INTENT NO. 2414
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 16 T. 22 S N/S R. 61 E CLARK County
PERMIT NO. 48614 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Repl. Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Kalichi		2	5	3
Brn. Clay + Gravel		5	45	40'
Brn Clay + Boulders		45	49	4'
Brn Clay + S. gravel		49	135	86'
Brn Clay + Boulders		135	160	25'
White Clay + Gravel		160	180	20
Brn Clay + Boulders		180	190	10'
Gravel + Brn Clay	Min	190	203	13'
Part Cement Gravel				
W/ Siems Brn Clay	✓	203	240	37

RECEIVED
JUL 24 1986
Div. of Water Resources
Branch Office: Las Vegas, NV

Date started MAY 12, 1986
Date completed MAY 14, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 240' feet
Casing record 8" .156 W/T
Weight per foot ..... Thickness .156

Diameter	From	To
8" inches	+1 feet	238 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 52' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 1/4" x 6"
From 197 feet to 238 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 144 feet below land surface
Flow 75 G.P.M. ..... P.S.I.
Water temperature Hot °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name J&M Well Service (Contractor)
Address 236 Mesa Verde Lane (Contractor)
Nevada contractor's license number 020295
Nevada contractor's drillers number
Nevada driller's license number 1478 (Actual Driller)
Signed [signature] (Contractor)
Date 5-16-86

(Rev. 6-81)

USE ADDITIONAL SHEETS IF NECESSARY

O-627 CR434