



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8204

PRINT OR TYPE ONLY

1. OWNER Ed Anderson ADDRESS AT WELL LOCATION _____
MAILING ADDRESS P. O. Box 60511 25 Sierra View
Reno, Nv 89506
2. LOCATION NE 1/4 SE 1/4 Sec. 19 T. 21 N/S R. 18 E. Washoe County
PERMIT NO. 81-140-06 Parcel No. _____ Subdivision Name _____
Issued by Water Resources _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Broken rock and overburden		0	6	6
Sediment layer tanish greenish in color gravels and loam		21	131	110
rock and cobbles and sands coarse	X	131	178	47
T.D. 178				

8. 10"-50' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 174 feet
Casing record 6"
Weight per foot 10.78 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>174</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
Depth of seal 50' feet
Gravel packed: Yes No
Gravel packed from 50 feet to 174 feet

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 154 feet to 174 feet
From _____ feet to _____ feet

Date started 12/9/86, 19_____
Date completed 12/10/86, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop.			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 90 feet below land surface
Flow 80+ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling and Well Service, Inc.
Address 2255 Glendale Ave. Sparks, Nv 89431
Nevada contractor's license number 15291
issued by the State Contractor's Board
Nevada contractor's driller's number 1132
issued by the Division of Water Resources
Nevada driller's license number issued by the 1132
Division of Water Resources, the on-site driller
Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
Date Roger M. Thrall 12/10/86