WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28029
Permit No.
Basin 87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8008

1. OWNER ROGER FENSKE
MAILING ADDRESS 8170 Blackfoot Way
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 2045 Applegate
Virginia City, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 6 T. 17 N/S R. 21 E. Storey County
PERMIT NO. Issued by Water Resources | Parcel No. | Virginia City Highlands Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill dirt		0	5	5
Soft brown clay		5	6	1
Brown clay		6	38	32
Soft zone		38	39	1
Brown clay		39	60	21
Weathered gray andasite		60	90	30
Gray andasite		90	126	36
Gray clay		126	160	34
Yellow clay		160	195	35
Gray andasite		195	278	83
Fracture (approx. 3-4GPM)	X	278	279	1
Gray andasite		279	310	31
Soft gray andasite with clay streaks		310	330	20
Gray andasite		330	335	5
Fracture	X	335	336	1
Gray andasite		336	350	14

Date started 12-15-86, 19
Date completed 12-18-86, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 350 feet
6 inches
inches
Casing record 350 ft. casing installed
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	350 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 350 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 278 feet to 298 feet
From 318 feet to 338 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 237 feet below land surface
Flow 25 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, Nevada 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 22, 1986

(Rev. 10-83) USE ADDITIONAL SHEETS IF NECESSARY. (O) 627