

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1286

PRINT OR TYPE ONLY

1. OWNER Ralph Poole ADDRESS AT WELL LOCATION 1075 Amarillo Dr. Minden, Nev.
 MAILING ADDRESS _____
 2. LOCATION W. of SE 1/4 of SE 2, 17T, 12N R. 20E Douglas County
 PERMIT NO. _____ Lot 2 Subdivision Name Chambers Fields
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Rock and topsoil</u>		<u>0</u>	<u>15</u>	<u>15</u>
<u>Cobblestones</u>	<u>Yes</u>	<u>15</u>	<u>75</u>	<u>60</u>
<u>Sand and gravel</u>	<u>Yes</u>	<u>75</u>	<u>102</u>	<u>27</u>

8. WELL CONSTRUCTION
 Diameter 8 inches Total depth 102 feet
 Casing record 102
 Weight per foot _____ Thickness .108
 Diameter From To
8 inches 0 feet 102 feet
 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory saw slot
 Size perforation 3 3/4" x 4"
 From 80 feet to 102 feet

Date started 12-31-86
 Date completed 1-5-87

9. WATER LEVEL
 Static water level 23 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold Quality Good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge. EM D L CO, INC.
 Name Edmund Miller Drilling and
Lead Co, Inc. Contractor
 Address Box 92, Artist View,
Smith, NV 89430 Contractor
 Nevada contractor's license number
 issued by the State Contractor's Board 24149
 Nevada contractor's driller's number
 issued by the Division of Water Resources 24149
 Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller 24149
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date 1-5-87

30+ BAILER TEST
 G.P.M. 30+ Draw down 5 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours