WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28035
Permit No.
Basin 6-88 Pleasant V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8097

1. OWNER CLYDE SUMMERS
MAILING ADDRESS 74 Arndell way, Sparks, NV 89431
ADDRESS AT WELL LOCATION 20211 395 S, Carson City, NV — Hwy 395 S & Pleasant Valley

2. LOCATION SW ¼ SW ¼ Sec. 5 T. 17N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Pleasant Valley (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose brown clay with broken rock		0	4	4
Brown clay with broken rock		4	18	14
Light brown clay		18	97	79
Soft zone		97	98	2
Light brown clay with some broken rock		98	166	68
Dark brown clay		166	173	7
Light brown clay with some broken rrock		173	195	22
Black broken volcanic rock		195	205	10
Broken fractured rock	X	205	210	5
Black broken volcanic rock		210	225	15

Date started 12-29-86, 19
Date completed 12-30-86, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 225 feet
6 inches
inches
Casing record 225ft. casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	225 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 225 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 79 feet below land surface
Flow 25 G.P.M. P.S.I.
Water temperature warm °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, Nevada 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date December 31, 1986

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627