WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28037
Permit No. 51767
Basin 108-Mason V

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 68

1. OWNER CLARENCE MORFOA
MAILING ADDRESS 140 FARRELL LN.
YERINGTON NV 89447

ADDRESS AT WELL LOCATION SAME AS LEGAL

2. LOCATION NW ¼ NE ¼ Sec. 12 T. 14 N/S R. 24 E/W Lyon County
PERMIT NO. 47055 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☒ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	5	5
COARSE SAND + GRAVEL		5	15	10
ALLUVIAL FILL	X	15	90	75
ALLUVIAL FILL w/				
CLAY STRATAS	X	90	130	40
ALLUVIAL FILL	X	130	170	40
COARSE SAND +				
GRAVEL	X	170	180	10
SEDIMENTARY FILL		180	184	4
ALLUVIAL FILL	X	184	190	6
CLAY w/ SAND STRATAS	X	190	204	14
TEST HOLE				
[redacted]				
CLAY W/ SAND				
STRATAS		204	210	6
COARSE SAND + CLAY		210	230	20
CLAY + SAND		230	250	20
BLUE CLAY		250	260	10
BLUE + BROWN CLAY		260	265	5
COARSE SAND		265	274	9
BROWN CLAY		274	280	6
BLUE CLAY		280	347	67

Date started 12-5, 1986
Date completed 12-18, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole #1, #2 inches Total depth 205' feet
Casing record
Weight per foot ..... Thickness 219

Diameter	From	To
#1) 24" inches	0' feet	60' feet
#2) 20" inches	60' feet	205' feet
inches	feet	feet
CASING inches	feet	feet
12 5/8 inches	(+) 1' feet	204' feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 204' feet

Perforations:
Type perforation SAWED
Size perforation 7/64 x 3" x 24 ROWS
From 117' feet to 204' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 21' feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature COLD ° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS DRILLING (Contractor)
Address 162 N. BYBEE LN. YERINGTON, NV. 89447 (Contractor)
Nevada contractor's license number 15646
Nevada contractor's drillers number 530, 780
Nevada driller's license number 530 (Actual Driller)
Signed Billy Ogden (Contractor)
Date 12-18-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434