



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8094

1. OWNER EARL E. YORK ADDRESS AT WELL LOCATION 5505 Winnemucka Ranch Road Reno, Nevada
 MAILING ADDRESS 10175 Calle Maria Reno, Nevada 89506

2. LOCATION NE 1/4 SW 1/4 Sec. 2 T. 22N N/S R 10E E. Washoe County
 PERMIT NO. Portion of #30119 - 076-120-1726 Palomino Valley 13 22-7-7
 issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown sandy clay		1/2	6	5 1/2
Soft loose sandy clay with DG		6	40	34
Soft weathered granite		40	86	46
Weathered granite		86	121	35
Weathered granite with clay streaks		121	151	30
Hard gray granite		151	154	3
Soft zone		154	161	7
Weathered granite		161	185	24
Fracture	X	185	187	2
Gray granite with clay streaks		187	207	20
Gray granite		207	249	42
Soft zone	X	249	257	8
Weathered granite		257	260	3
Soft zone	X	260	267	7
Granite		267	274	7
Soft zone		274	282	8
Gray granite		282	290	8

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 290 feet
6 inches
6 inches

Casing record 290 ft. casing installed
 Weight per foot 156 Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>290</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 290 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 180 feet to 220 feet
 From 240 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 12-3-86, 19____
 Date completed 12-5-86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL
 Static water level 79 feet below land surface
 Flow 37 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, Nevada 89510 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 8, 1986