WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28042
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8446

1. OWNER Gary Lebhard Co
MAILING ADDRESS 306 W Musser
Carson City, NV 89701

ADDRESS AT WELL LOCATION 2613 Gordon Johnson Lane
Minden Nevada

2. LOCATION SE ¼ SW ¼ Sec. 34 T. 14 N/S R. 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 21-203-05 (Parcel No.) Home (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Fine to Course Sand with lense of Clay		4	87	83
Tight Clay, gray		87	94	7
Gravels, fine to Course, ½", with sand	✓	94	118	22
Yellow, Tight Clay		118	120	2
T.D. = 120'				

Date started Jan 29, 19 87
Date completed Jan 30, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed well with Clear water to remove bentonite. Developed well with 250 PSI Air for 2 Hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 11 3/4 to 20 inches Total depth 120 feet
Casing record 6 5/8 OD
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 51 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 51 feet to 120 feet

Perforations:
Type perforation Hi-Slot Factory
Size perforation 3½ x 3½
From 98 feet to 118 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 41 feet below land surface
Flow 50+ G.P.M. P.S.I.
Water temperature Cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor) #3
Address 5551 Hwy 50 Carson City, NV 89701 (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Clinton R Butt (Actual Driller) (Contractor)
Date Jan 30, 1987

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434