WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28050
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7416

1. OWNER Kirk Thompson
MAILING ADDRESS Box 2435
Gardnerville, NV

ADDRESS AT WELL LOCATION Unit 2 Lot 25 Blk C
612 Stagecoach Road
Gardnerville, Nev

2. LOCATION NE ¼ NE ¼ Sec. 25 T. 12 N/S R. 20 E Douglas County
PERMIT NO. (Issued by Water Resources) 29-43301 (Parcel No.) Thompson Acres (Subdivision Name) Rheunstrith Flat

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Cemented Sand & gravels		3	87	84
Soft, fine Sand		87	103	16
Cemented Sand & gravels		103	217	114
Gravel, fine to 3/8"	✓	217	240	23
T.D. 240 FT				

Date started Jan 14, 1957
Date completed Jan 20, 1957

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with 250 psi air to clean & gravel pack for 3 hours			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. 10¾ to 60' WELL CONSTRUCTION
Diameter hole ..... inches Total depth ..... feet
Casing record 6⅝" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	+2 feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 240 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 + 3½
From 215 feet to 235 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 147 feet below land surface
Flow 10 G.P.M. ..... P.S.I.
Water temperature Cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor) #3
Address 5551 Hwy 50 Carson City, NV 89701 (Contractor)
Nevada contractor's license number 23775
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Quinton R Butts (Actual Driller) (Contractor)
Date Jan 21, 1957

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434