

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8210

1. OWNER Ernest W. Hope ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1700 Watt ST 215 McClellan
Reno, Nv 89509
 2. LOCATION NE 1/4 SW 1/4 Sec 32 T 17 N/S R 20 E Washoe County
 PERMIT NO. 050-398-13 - New Washoe City Subdivision Name
Issued by Water Resources Parcel No.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy D.G.		0	14	14
D. G.		14	120	106
Very hard D.G. fractured		120	268	148
T.D. 268'				

8. 10"- 60' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 268 feet
6 1/2 inches
 inches
 Casing record 6 5/8
 Weight per foot 10.78 & 12.92 Thickness .156 & .188
 Diameter From To
6 5/8 inches +1 feet 218 feet
 inches feet feet
5 inches 208 feet 268 feet
 inches feet feet
 inches feet feet
 inches feet feet
 Surface seal: Yes No Type grout 7 1/2 yards
 Depth of seal 60' feet
 Gravel packed: Yes No
 Gravel packed from 60 feet to 70 only feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 198 feet to 218 feet
 From 248 feet to 268 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 1/6/87 19____
 Date completed 1/9/87 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours
G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 70 feet below land surface
 Flow 10 G.P.M. P.S.I.
 Water temperature cool °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
Contractor
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1132
 Division of Water Resources the on-site driller
 Signed Roger M. Thrall
By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 1/12/87