WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28079 (T)
Permit No. Dom Egrn
Basin WASHOE V 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7381

1. OWNER Young Enterprizes
MAILING ADDRESS 4270 Shoreshore Lane Reno, Nev
ADDRESS AT WELL LOCATION 2075 Lakeshore Drive East Washoe Carson City, NV 89701

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. [illegible] | 50-531-01 | parcel C Map 2034
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with fine sand		0	15	15
Fine grey silt with clay lense	✓	15	83	68
Grey silt with small gravel		83	117	34
Pea gravel, ¼" & smaller, multi colored	✓	117	140	23
T.D. 140'				

Date started January 8, 1987
Date completed January 9, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
developed well with fresh water after gravel packing			
Tremied seal from 53'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 60 inches Total depth 140 feet
Casing record 6 5/8 O.D.
Weight per foot 11.7 LFT Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 53 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 53 feet to 140 feet

Perforations:
Type perforation Mill slot, Factory
Size perforation 3/32 x 3 1/2
From 115 feet to 135 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 15 feet below land surface
Flow 40 G.P.M. ..... P.S.I.
Water temperature Cool ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co.
Contractor
Address 5551 Hwy 50 E Unit 3 Carson City Nev 89701
Contractor
Nevada contractor's license number 23295
Nevada contractor's drillers number .....
Nevada driller's license number 1472
Actual Driller
Signed Quinton R Butts
Contractor
Date January 10, 1987

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434