WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28081
Permit No.
Basin 8-105 Carson

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 844-3

1. OWNER Scott Stice
MAILING ADDRESS 3451 Tourmaline Way
Minden, Nevada

ADDRESS AT WELL LOCATION Tamara Court
Lot 12 Book 580 Page 266

2. LOCATION NE ¼ SE ¼ Sec. 30 T. 14 N/S R. 20 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name Dangberg Estates

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden with Clay | | 0 | 3 | 3 |
| Sandy Loam | | 3 | 67 | 64 |
| Tight Clay | | 67 | 76 | 9 |
| Gravel, fine to Coarse | ✓ | 76 | 118 | 32 |
| Clay Seam | | 118 | 121 | 3 |
| T.D. 121' | | | | |
| T.D. = 120 FT | | | | |

Date started 12/30, 1986
Date completed 12/31, 1986

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| Developed Well with air to remove drill mud and to gravel pack. pumped seal using a tremie System | | | |

BAILER TEST

G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION

Diameter hole 12 3/4" inches Total depth 120 feet
Casing record 8 5/8" O.D.
Weight per foot 16.9/FT Thickness .188

| Diameter | From | To |
|---|---|---|
| 3 5/8 inches | +2 feet | 120 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3 1/2
From 57 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL

Static water level Flowing - Shut in feet below land surface
Flow 70+ G.P.M. ____ P.S.I.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H Pump Co.
Contractor
5551 Hinsdale Rd #3
Address Carson City, NE 89701
Contractor

Nevada contractor's license number 23295

Nevada contractor's drillers number

Nevada driller's license number 1472
Actual Driller

Signed Quinton R Butts
Contractor

Date 12/31/86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434