

OFFICE USE ONLY
 Log No. 28083
 Permit No. 50399
 Basin ANTELOPE V.

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5964

1. OWNER The International Church of Christ ADDRESS AT WELL LOCATION Peak Dr. Canyon Valley
 MAILING ADDRESS 640 Ralston Reno 1210 Argonaut Way, Reno
 2. LOCATION NE 1/4 NW 1/4 Sec. 35 T. 22 N. S. R. 19 Washoe County
 PERMIT NO. 50399 79-440-10 Parcel No. Redrock Ranch estates #295 Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. QM PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sand (Br.)</u>		<u>0</u>	<u>26</u>	<u>26</u>
<u>sandy clay</u>		<u>26</u>	<u>124</u>	<u>98</u>
<u>D.G.</u>		<u>124</u>	<u>213</u>	<u>89</u>
<u>sand</u>		<u>213</u>	<u>244</u>	<u>31</u>
<u>D.G. w/ granite layers</u>	<u>X</u>	<u>244</u>	<u>337</u>	<u>93</u>

8. WELL CONSTRUCTION
 Diameter 14 inches Total depth 337 feet
 Casing record
 Weight per foot _____ Thickness 1.88

Diameter	From	To
<u>8 7/8 o.d.</u> inches	<u>0</u> feet	<u>337</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type grout
 Depth of seal 58 feet
 Gravel packed: Yes No
 Gravel packed from 58 feet to 337 feet
 Perforations:
 Type perforation factory sawed
 Size perforation 1/8" x 2 1/2"
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 12.4 1986
 Date completed 12.20 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>airlift</u>	<u>est. 400</u>		<u>3</u>

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level approx. 30 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Williams & Sons
 Address 22 So. Patterson, Sparks, Nev.
 Nevada contractor's license number issued by the State Contractor's Board 14483
 Nevada contractor's driller's number issued by the Division of Water Resources 957
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 957
 Signed Paul E. Williams sr.
 By driller performing actual drilling on site or contractor
 Date 12-30-86