



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8456

1. OWNER Kenneth Wylie ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS P.O. Box 2128 FALLOW RD. FALLOW, NV.  
FALLOW, NV. 89406

2. LOCATION SW 1/4 SW 1/4 Sec. 18 T. 19 N/S R. 28 E. Churchill County  
PERMIT NO. none Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
New Well  Recondition   
Deepen  Other

4. PROPOSED USE  
Domestic  Irrigation  Test   
Municipal  Industrial  Stock

5. TYPE WELL  
Cable  Rotary   
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>OVERBURDEN</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>CLAY, BROWN</u>	<u>0</u>	<u>7</u>	<u>21</u>	<u>6</u>
<u>CEMENTED GRAVEL</u>	<u>15</u>	<u>21</u>	<u>23</u>	<u>2</u>
<u>SAND, BROWN, FINE</u>	<u>0</u>	<u>23</u>	<u>47</u>	<u>24</u>
<u>with CLAY mixed</u>	<u>0</u>	<u>47</u>	<u>51</u>	<u>4</u>
<u>SAND GRAY MED.</u>	<u>0</u>	<u>51</u>	<u>53</u>	<u>2</u>
<u>CLAY, GRAY</u>	<u>15'</u>	<u>53</u>	<u>54</u>	<u>1</u>
<u>GRAVEL, BROWN w/B</u>		<u>54</u>	<u>55</u>	<u>1</u>
<u>SAND, BROWN, COARSE</u>		<u>55</u>	<u>57 1/2</u>	<u>2 1/2</u>
<u>GRAVEL, BROWN</u>				

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 57 1/2 feet

Casing record 58 1/2 inches

Weight per foot 17.02 Thickness .250

Diameter	From	To
<u>6</u> inches	<u>+1</u> feet	<u>57 1/2</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type NEET

Depth of seal 25 feet

Gravel packed: Yes  No

Gravel packed from 56 1/2 feet to 57 1/2 feet

Perforations:  
Type perforation Torch  
Size perforation 3/2 x 5"

From 52 1/2 feet to 57 1/2 feet

Date started 1-3- 1987  
Date completed 1-7- 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>25</u>	<u>10</u>	<u>2hrs</u>
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 11-7 feet below land surface

Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature Cold °F Quality EXCELLENT

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WATER-RITE WELL DRILLING  
Address P.O. Box 883 FALLOW, NV. 89406

Nevada contractor's license number issued by the State Contractor's Board 0023978

Nevada contractor's driller's number issued by the Division of Water Resources 1473

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473

Signed Harold P. Olson  
By driller performing actual drilling on site or contractor

Date 1-7-87

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____