WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28095
Permit No. DOMESTIC
Basin 70

0748

1. OWNER Pat /Jane Schommer ADDRESS P.O. Box 1711 Winnemucca, Nv.
Parcel # D

2. LOCATION ¼ S.E. ¼ Sec. 12 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil sandy brown		0	2	2
Gravel brown		2	59	57
Gravel-w-strips of clay		59	93	34
Gravel brown	W.B.	93	109	16
Clay-w-strips of sand & gravel	W.B.	109	130	21

Date started July 2, 19 83
Date completed July 18, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 40 Draw down 2 feet 1½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 6 8 inches Total depth 130 feet
Casing record 8 inch
Weight per foot 15 Thickness 156

Diameter	From	To
8 inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 1/8" by 4 inch
From 98 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 80 Feet below land surface
Flow 40 G.P.M.
Water temperature 54 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name T & R WELL DRILLING
Address 9015 S. Grassvalley Rd. Winnemucca Nevada 89445
Nevada contractor's license number 017721
Nevada driller's license number 1190
Signed July 26, 1983
Date Tom Stile

USE ADDITIONAL SHEETS IF NECESSARY

O 627