WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28099
Permit No.
Basin 4-45

1. OWNER Don Wilson ADDRESS LaMoille, Nev

2. LOCATION NE ¼ NE ¼ Sec. 24 T. 33 N/S R. 57 E. Elko County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	3	3
Sandy Clay		3	57	54
Sandy Clay & gravel		54	125	71

RECEIVED
AUG 17 1983
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started July 13, 1983
Date completed July 14, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 125 feet
Casing record 125
Weight per foot 10.56 Thickness .156

Diameter	From	To
10 inches	0 feet	50 feet
8 inches	50 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 125 feet to 50 feet

Perforations:
Type perforation Factory
Size perforation 1/8 x 2
From 125 feet to 105 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 Feet below land surface 40
Flow ..... G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name B.B. Bailey
Address P.O. Box 651 Mt Home Ida.
Nevada contractor's license number 015356
Nevada driller's license number 1072
Signed B.B. Bailey
Date July 16, 1983

USE ADDITIONAL SHEETS IF NECESSARY

O-627