

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8487

PRINT OR TYPE ONLY

1. OWNER JANE KIZZIAR ADDRESS AT WELL LOCATION 11850 Overland Road
MAILING ADDRESS 11630 Juniper Lane Reno, Nevada 89506
SE 1/4 NW 1/4 Sec 15 T. 21N N/S R. 19 E Washoe County
2. LOCATION SE 1/4 NW 1/4 Sec 15 T. 21N N/S R. 19 E Washoe County
PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
New Well Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock

5. TYPE WELL
Cable Rotary
Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL DEEPENING</u>				
Gray weathered granite		175	181	6
Soft fracture granite				
(approx 2GPM)	X	181	190	9
Weathered granite		190	205	15
Fracture granite (NO WATER)		205	211	6
Weathered granite with clay streaks		211	213	2
Weathered soft granite		213	217	4
Gray granite		217	222	5
Fracture	X	222	223	1
Weathered granite		223	236	13
Weathered soft granite		236	250	14

Date started 1-30-87, 19____
Date completed 1-30-87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter _____ inches Total depth 250 feet
_____ 6 inches
_____ inches

Casing record 250 ft. steel liner installed
Weight per foot _____ Thickness .156

Diameter	From	To
6 inches	0 feet	250 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type N/A
Depth of seal _____ feet
Gravel packed: Yes No
Gravel packed from 175 feet to 250 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From _____ feet to _____ feet
From 196 feet to 236 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 140 feet below land surface
Flow 20 G.P.M. _____ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc.
Contractor
Address P.O. Box 12370, Reno, NV 89510
Contractor
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Wayne Drilling, Inc.
By driller performing actual drilling on site or contractor
Date February 5, 1987