WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28133
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7406

1. OWNER Robert Anderson
MAILING ADDRESS Gardnerville, Nevada
ADDRESS AT WELL LOCATION Dina Court, Lot 4D Gardnerville Nevada

2. LOCATION NE ¼ NE ¼ Sec. 23 T. 12 N/S R. 19 E/W Douglas County
PERMIT NO. SW (Issued by Water Resources) 19-280-63 (Parcel No.) Theresa Development (Subdivision Name)

3. TYPE OF WORK NEW APN: 1219-23-002-006
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐
4/21/2011

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/Granite Boulders		0	6	6
D.G. and Granite boulders		6	85	79
Fractured Granite with iron stains		79	105	26
Fractured Granite with Water	✓	105	137	32
Total depth 137'				

Date started Feb 2, 1987
Date completed Feb 4, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed Well For 3 HRS With 450 CFM 250 PSI Air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4" inches Total depth 137 feet
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	137 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 52 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 52 feet to 137 feet

Perforations:
Type perforation Mill slot Factory
Size perforation 3/32 x 3 1/2"
From 116 feet to 136 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 63 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature 60° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co. (Contractor)
Address 5551 Hwy 50 Unit 3 Carson City, Nev 89701 (Contractor)
Nevada contractor's license number 23225
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Rusinton R Betts (Actual Driller)
(Contractor)
Date Feb 4, 1987

(Rev. 6-81)
USE ADDITIONAL SHEETS IF NECESSARY
O-627 CR434