

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 7864

PRINT OR TYPE ONLY

1. OWNER Mac Calico ADDRESS AT WELL LOCATION Stagecoach, NV  
 MAILING ADDRESS 8675 Highway 50 West  
Stagecoach, NV 89429

2. LOCATION NW 1/4 Sec. 11 T. 17N N/S R. 23 E Lyon County  
 PERMIT NO. lot c of lot 10 Rancho Subdivision #2 Subdivision Name  
 Issued by Water Resources Parcel No.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay sand		0	20	
sand gravel clay		20	40	
clay gravel		40	60	
sand gravel	XX	60	80	
sand gravel clay		80	100	
sand gravel		100	120	
sand gravel		120	140	
sand clay gravel		140	165	

8. WELL CONSTRUCTION

Diameter 12 inches Total depth 165 feet  
8 inches  
8 inches

Casing record 188 X 8 5/8 X 5/32  
 Weight per foot 14.11 Thickness 5/32

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>50</u> feet
<u>8</u> inches	<u>50</u> feet	<u>165</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:  
 Type perforation 188.8/58 saw cut  
 Size perforation 3/32  
 From 120 feet to 165 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1-26 1987  
 Date completed 1-29 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 30 Draw down 10 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 70 feet below land surface  
 Flow good G.P.M. 20-30 P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sierra Pump & Drilling Contractor  
 Address 4639 Highway 50 East Carson City Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 012236-B  
 Nevada contractor's driller's number issued by the Division of Water Resources 1393  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1393  
 Signed Curtis Blodgett By driller performing actual drilling on site or contractor  
 Date 2-4-87