

Log No. 28167
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 2438

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Norman Bonnett ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION N 1/2 1/4 N 1/2 1/4 Sec. 29 T. 21 S. R. 53 E. Uye County
 PERMIT NO. _____
 Issued by Water Resources Parcel No. Lot 577 Subdivision Name Green Saddle Ranch

| | | |
|---|--|---|
| 3. TYPE OF WORK | 4. PROPOSED USE | 5. TYPE WELL |
| New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> | Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> | Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> |
| Deepen <input type="checkbox"/> Other <input type="checkbox"/> | Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/> | Other <input type="checkbox"/> |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------|--------------|------|-----|------------|
| Clay | | 0 | 47 | 47 |
| Shale | | 47 | 51 | 4 |
| Clay | | 57 | 97 | 40 |
| Shale | X | 97 | 100 | 3 |
| Clay | | 100 | 137 | 37 |
| Shale | X | 37 | 41 | 4 |
| Clay | | 141 | 160 | 19 |

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 160 feet

Casing record 8 3/4 inches

Weight per foot 14.11 Thickness 1.56

| Diameter | From | To |
|---------------------|---------------|-----------------|
| <u>8 3/4</u> inches | <u>1</u> feet | <u>160</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type CMT

Depth of seal _____ feet

Gravel packed: Yes No

Gravel packed from 120 feet to 160 feet

Perforations:

Type perforation Torch

Size perforation 1/8 x 6

From 120 feet to 160 feet

From _____ feet to _____ feet

RECEIVED

FEB 17 1987

Div. of Water Resources
 Branch Office Las Vegas, NV

Date started 10/1 1986
 Date completed 10/3 1986

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL

Static water level 60 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Custom Drilling Inc Contractor

Address 4425 Steady Ave L.V. Contractor

Nevada contractor's license number issued by the State Contractor's Board 19219

Nevada contractor's driller's number issued by the Division of Water Resources 1081

Nevada driller's license number issued by the Division of Water Resources, the on-site driller _____

Signed [Signature] By driller performing actual drilling on site or contractor

Date 10/15/86

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |