

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2435

PRINT OR TYPE ONLY

1. OWNER RUSSELL Rupert ADDRESS AT WELL LOCATION _____
MAILING ADDRESS _____

2. LOCATION SW 1/4 SE 1/4 Sec 20 T 21 S N/S R 54 E DYE County _____
PERMIT NO. 503 Parcel No. _____ Subdivision Name Green Saddle Ranch

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	37	37
Clay		37	47	10
Clay		47	95	48
Clay	X	95	105	10
Clay	+	105	135	30
Clay		135	146	5
Clay		146	160	20

8. WELL CONSTRUCTION
Diameter 12 1/4 inches Total depth 160 feet
Casing record 8 3/8 inches
Weight per foot 14.11 Thickness 156
Diameter From To
8 3/8 inches -1 feet 160 feet
Surface seal: Yes No Type CMT
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 160 feet
Perforations:
Type perforation Torch
Size perforation 1/8 x 6
From 120 feet to 160 feet

RECEIVED
FEB 17 1987
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-15, 1986
Date completed 9-17, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
Static water level 60 feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Custom Drilling Inc
Address 4425 Stacey Ave
Nevada contractor's license number issued by the State Contractor's Board 19219
Nevada contractor's driller's number issued by the Division of Water Resources 1081
Nevada driller's license number issued by the Division of Water Resources the on-site driller _____
Signed [Signature]
Date 9-30-86

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours