



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4386

PRINT OR TYPE ONLY

1. OWNER Earl & Nadine Stellman ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 SE 1/4 Sec. 9 T. 20S N/S R. S3 E \_\_\_\_\_ County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. Basin Road Estates Lot 1 Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	6	6
Caliche		6	11	5
Clay		11	36	25
Caliche		36	38	2
Clay		38	46	8
Caliche	WB	46	49	3
Clay		49	76	27
Caliche	WB	76	80	4
Clay		80	115	35
Caliche	WB	115	118	3
Clay		118	131	13
Caliche	WB	131	140	9
Clay		140	149	9
Caliche	WB	149	156	7
Clay		156	160	4

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 160 feet  
 Casing record 160 Ft 8 7/8 inch.  
 Weight per foot 14.11 Thickness 156  
 Diameter 8 7/8 inches From -1 feet To 160 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 160 feet  
 Perforations:  
 Type perforation Torch  
 Size perforation 1/8 inch by 6 inch  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 DEC 23 1986  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL

Static water level 32 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name STH Drilling Contractor  
 Address HCR Box 70906 Pahrump Contractor  
 Nevada contractor's license number 22059  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 1426 Actual Driller  
 Signed Steve Hammett Contractor  
 Date 11-20-86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours