



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Robert Bentz ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Pahrump, Nev 89041

2. LOCATION NW 1/4 SW 1/4 Sec. 19 T. 21-S N/S R. 54 E Nye County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay		4	16	12
Grey Clay		16	38	22
Brown Clay		38	62	24
Hard Lime		62	68	6
Brown Clay		68	80	12
Hard Lime	x	80	84	4
Grey Clay	x	84	102	18
Hard Lime		102	110	8
Grey Clay	x	110	138	28
Hard Lime		138	146	8
Brown Clay	x	146	160	14

8. WELL CONSTRUCTION  
 Diameter 12 inches Total depth 160 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 160 ft. of 8 in casing  
 Weight per foot 18 lbs. Thickness 188  

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 160 feet  
 Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4 in width 8 in long  
 From 100 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 FEB 06 1987  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started January 30, 1987  
 Date completed January 30, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 46 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg  
 Address St. Rt. Box 36525  
 Nevada contractor's license number issued by the State Contractor's Board 7484  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg  
 Date February 4, 1987

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. 20 gals. Draw down 4 feet 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours