

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 28204
 Permit No. _____
 Basin _____

NOTICE OF INTENT NO. 4366

PRINT OR TYPE ONLY

1. OWNER Verdin & Margaret Eggenberger ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Pahrump, Nevada 89041

2. LOCATION NW 1/4 SE 1/4 Sec. 33 T. 20-S N/S R. 53 E. Nye County _____
 PERMIT NO. _____ Issued by Water Resources Parcel No. 31 Subdivision Name Palo Verde Subdivision

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
White Clay		4	12	8
Soft brown Clay		12	38	26
White Clay	x	38	54	16
Brown Clay	x	54	102	48
Grey Clay	x	102	126	24
Brown Clay	x	126	140	14

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 140 feet
 Casing record 140 ft. of 8 in casing
 Weight per foot 18 lbs. Thickness 188
 Diameter From To
12 inches 0 feet 140 feet
 _____ inches _____ feet _____ feet

Surface seal: Yes No Type concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 140 feet

Perforations:
 Type perforation torch cut
 Size perforation 1/4 in width 8 in long
 From 80 feet to 140 feet
 From _____ feet to _____ feet

RECEIVED

DEC 18 1986

Div. of Water Resources
 Branch Office - Las Vegas, NV
 Date started November 17 19 86
 Date completed November 17 19 86

9. WATER LEVEL

Static water level 35 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Charles Nyberg Contractor
 Address St. Rt. Box 36525 Contractor
 Nevada contractor's license number 7484
 Nevada contractor's drillers number _____
 Nevada driller's license number 725 Actual Driller

BAILER TEST
 G.P.M. 20 gals. Draw down 4 feet 1/4 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed Charles Nyberg Contractor
 Date December 16, 1986