

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8133

PRINT OR TYPE ONLY

1. OWNER Pierre Mosser ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 3485 Frost Lane 3500 Frost Lane
Reno, Nevada Reno, Nevada
2. LOCATION SW 1/4 SE 1/4 Sec. 2 T. 18 N. 19 E. Washoe County
PERMIT NO. None 041-092-30 Frost Ranches
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock Other
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Boulders		0-	9	
Brown Clay		9	40	
Course Sand		40	46	
Brown Clay & Sand		46	58	
Course Sand		58	61	
Brown Clay		61	64	
Course Sand		64	69	
Brown Clay		69	75	
Brown Clay & Sand		75	83	
Brown Clay		83	85	
Clay & Gravel		85	89	
Red Volcanic Rock	xx	89	160	

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 160 feet
Casing record 6" I.D.
Weight per foot _____ Thickness .156
Diameter From To
6 inches -1 feet 160 feet
_____ inches _____ feet _____ feet
Surface seal: Yes No Type Neat Cement
Depth of seal 54' feet
Gravel packed: Yes No
Gravel packed from 54' feet to 160' feet
Perforations:
Type perforation Mill Slot
Size perforation 1/8"
From 120' feet to 160' feet
From _____ feet to _____ feet

9. WATER LEVEL
Static water level Flowing feet below land surface
Flow 2 G.P.M. not tested P.S.I.
Water temperature cool °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams and Sons Contractor
Address 22 So. Patterson Sparks Contractor
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 1418 Actual Driller
Signed Bruce Miller Contractor
Date 3-29-87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

AIR
BARRIER TEST
G.P.M. 25 Draw down 155 feet 1 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours