WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No.
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8470

1. OWNER Charles W. Herron
MAILING ADDRESS Virginia City, Nevada
ADDRESS AT WELL LOCATION Comstock Dumbers, Brewster Way

2. LOCATION NE ¼ NW ¼ Sec. 36 T. 17 N/S R. 22 E W/S State County
PERMIT NO. Wlly 2711 (Issued by Water Resources) CBC 257-2 (Parcel No.) New Washoe City Lot 1 Blk. D (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ large Boulders		0	6	6
Firm to Hard Sandstone		6	122	116
Coarse gravel	✓	122	124	2
Hard Sandstone, No fractures		124	218	94
fractured Stone w/water	✓	218	221	3
Solid, hard Sandstone		221	316	97
fractured Sand Stone w/water	✓	315	319	1
Solid Sandstone		319	320	1
T.D. 320'				

Date started March 3, 1957
Date completed March 11, 1957

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air lift test [illegible]			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 18 34 tele inches Total depth 320 feet
7 7/8 inches
inches
Casing record 6-5/8"
Weight per foot 11.7 Thickness .156

Diameter	From	To
6-5/8 inches	12 feet	320 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Portland Cement
Depth of seal 52 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 52 feet to 320 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/16 x 3 1/2
From 320 feet to 320 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 78 feet below land surface
Flow 14 G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co. (Contractor)
Address 1351 Hungry Hollow Rd Carson City, Nev. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23795
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed William K. Bello (By driller performing actual drilling on site or contractor)
Date March 12, 1957

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627